

THE MUNICIPAL AUTHORITY OF THE BOROUGH OF WEST VIEW WATER DEPARTMENT
 210 PERRY HIGHWAY, PITTSBURGH, PA 15229
 412-931-3500 412-364-1257

Water Analysis

Calcium*	<u>122</u>	ppm Ca as CaCO ₃
Magnesium*	<u>36</u>	ppm Mg as CaCO ₃
Sodium*	<u>43</u>	ppm as Na
P. Alkalinity	<u>2</u>	ppm P. Alk. as CaCO ₃
Total Alkalinity*	<u>66</u>	ppm Total Alk. as CaCO ₃
Chloride*	<u>85</u>	ppm as Cl
Sulfate	<u>106</u>	ppm as SO ₄
Nitrogen	<u>0.99</u>	ppm as Nitrate
Nitrogen	<u><0.05</u>	ppm as Nitrite
Total Iron	<u>0.005</u>	ppm as Fe
Total Manganese	<u>0.015</u>	ppm as Mn
Chlorine	<u>0.3-1.2</u>	ppm as Cl ₂
Total Hardness*	<u>158</u>	ppm as CaCO ₃
Total Hardness*	<u>9.24</u>	grains/gal as CaCO ₃
Fluoride	<u>1.0</u>	ppm as F
Lead	<u><0.001</u>	ppm as Pb
Specific Conductance*	<u>554</u>	Micromhos/cm
pH	<u>8.3-8.5</u>	
Turbidity	<u>0.05</u>	NTU
Color	<u>1</u>	APHA Units
Total Dissolved Solids*	<u>277</u>	ppm
Average Trihalomethanes (THM) for last four quarters*	<u>0.044</u>	ppm
Average Haloacetic Acids (HAA) for last four quarters*	<u>0.008</u>	ppm
Total Coliforms per 100 mL	<u><1</u>	
* = will change seasonally		